



**Closing date: July 29, 2022**

Exhibitor

Hall / Stand no.

Outdoor exhibition area / Block

VAT no.

Contact

Street / P.O. Box

E-mail

Country / Town / Postcode

Tel. with area code and ext.

Fax with area code and ext.

**We hereby order—in the name and for account of the registered main exhibitor—subject to the conditions for connection and supply of sprinkler systems detailed on page 2. Orders in the name of co-exhibitors are not possible.**

Installation of a sprinkler system for covered stand area.

\_\_\_\_\_ m<sup>2</sup> of covered stand surface

Please tick	Item no.	Description	EUR
	38497	Main sprinkler connection (basic installation incl. 3 sprinkler nozzles)	1,385.00

Quantity	Item no.	Description	EUR/unit
	38499	Additional sprinkler nozzles	350.00

**The precise number and position of the sprinkler nozzles is determined after submission of the stand drawing.**

The basic installation can be expanded with additional sprinkler nozzles to a maximum of 18 sprinkler nozzles.

**Please note:**

The sprinkler pipes are not suitable for visible exposure. Clearance of 150 mm from the top edge of the ceiling to the steel structure is required for laying the sprinkler pipes.

**We will be erecting a raised platform on our stand (100 mm min. height clearance required for laying pipes):**

Yes, the clearance height between the floor of the hall and the raised platform is approx.

\_\_\_\_\_ cm

No

**Important: Prior to the commencement of your stand planning activities, kindly ask Messe München GmbH's Technical Exhibition Services Division to supply you with an extract of the plan of the stand area showing the location of the sprinkler supply lines in the utility ducts.**

**Please be sure to submit plans to scale marked accordingly (with arrow showing north as well as neighboring stands or other points of reference). Kindly mark/indicate on the plans too the location of the transfer point from the utility duct to the stand ceiling (stop valve with test unit on the stand to be accessible at all times).**

**Messe München GmbH reserves the right to charge an additional fee for late orders and plans.**

**Sprinkler connections cannot be made available in the ICM Foyer or in the entrance buildings.**

Place / date

Company stamp and legally binding signature of exhibitor

### ■ Connection and supply terms for sprinkler systems

Sprinkler systems must be installed according to the recognized technical standards and with the approval of the Munich Municipal Fire Department.

**The prices listed apply to installation heights of up to 3 m. Any additional costs incurred for installation heights of over 3 m and for special stand constructions (surface installations and for the bypassing of joists and stand components, etc.) are charged for.**

The complete documents (as described in form 1.3), orders and plans must be submitted to Messe München GmbH by the specified deadline at the latest (see "Important Notes"), however, for two-storied and covered stands no later than six weeks before the start of construction.

No guarantee can be given that installations ordered after this date will be completed on time.

**Messe München GmbH reserves the right to charge an additional fee for late orders.**

The sprinkler pipes are installed in the halls according to the dimensions specified in the plan. The position of the shut-off valve on the ground floor must be specified by the exhibitor/stand builder. The supply pipe will be laid if possible in the utility conduits but may be laid above ground if the position of the shut-off valve and the sprinkler installation downstream of it require this (on request, we will indicate the placement of the basic sprinkler pipe/outlet). The sprinkler installation itself is always installed in front of the walls and under the suspended ceilings. The sealed shut-off valve must remain accessible at all times and must not be built over or obstructed.

The exhibitor shall be liable for damage resulting from noncompliance with this regulation.

**The General Terms of Contract for Exhibitor Services of Messe München GmbH apply additionally.**

#### ■ Design data:

- Exhibition halls in accordance with VDS are in fire risk class BG 2.3.
- Maximum protection area per sprinkler nozzle 12 m<sup>2</sup> by means of glass bulb sprinkler DN 15, nominal opening temperature 68°C, color red.
- Separate cabins and rooms must also be provided with sprinklers in conformance with the maximum protection area of 12 m<sup>2</sup>/nozzle.
- A maximum of 18 sprinkler nozzles may be connected for each DN 50 connecting pipe in the utilities conduit. The pipe dimension of feeder pipes to the nozzles is also DN 50.
- Structures suspended from the hall ceiling (trusses, etc.) cannot be fitted with a sprinkler system.